



GENERAC GENERATOR PREVENTIVE MAINTENANCE SERVICE AGREEMENT



CUSTOMER NAME _____

CUSTOMER ADDRESS _____

CUSTOMER PHONE # _____ CELL # _____

E-MAIL ADDRESS _____ FAX _____

GENERATOR MODEL # _____ SERIAL # _____

Service will be performed semi-annually as outlined on page 2 of this agreement.

Price:

<input type="checkbox"/> 1 Year Maintenance Agreement.....	\$550.00
<input type="checkbox"/> 2 Year Maintenance Agreement	\$1000.00
<input type="checkbox"/> Autopay: \$40/month (\$480/year), save \$70 vs. the 1-year agreement	\$480.00
<input type="checkbox"/> Manufacturer's recommended oil & filter change after first 8-hours of operation	\$150.00
<small>(Units are shipped with a special light weight break-in oil and should be run under various load conditions, tested & oil change performed)</small>	

All additional maintenance or repairs will be subject to standard service rates.

I accept and agree to the maintenance agreement term selected above as detailed on page 2 of this agreement.

Customer Acceptance Signature Date

TERMS: All Purpose Construction and Electrical Services, Inc. agrees to provide the maintenance services described on page 2 for the period commencing upon payment of the charges set forth above and continuing for the one or two year Term selected by Customer. This Agreement will renew automatically for additional terms of one year each unless terminated by written notice at least 30 days prior to the end of the then current Term. This Agreement covers only the routine maintenance services specified on page 2. All required Parts and additional labor not covered by Manufacturer's warranty will be supplied at additional cost. All work will comply with manufacturer's guidelines and be performed in a professional manner and All Purpose Construction and Electrical Services, Inc. agrees to correct any non-conforming services provided hereunder promptly. All Purpose Construction and Electrical Services, Inc. disclaims all other warranties, express or implied. Customer agrees that in no event shall All Purpose Construction and Electrical Services Inc. be liable for indirect, consequential, special, exemplary or incidental damages of any kind arising out of this Agreement.

Form of Payment:

Amount Paid _____	<input type="checkbox"/> Cash <input type="checkbox"/> ACH	Date Paid _____
Visa/Master Card _____		Exp. Date _____
Name on Card _____		Security Code _____
Approval _____		



PREVENTIVE MAINTENANCE SCHEDULE
Air Cooled

I - Inspect C - Clean R - Replace

	Year 1		Year 2		Comments
	1st Half	2nd Half	1st Half	2nd Half	
FUEL					
Fuel Lines and connections	I	I	I	I	
Flexible Fuel Line	I	I	I	I	
LUBRICATION					
Oil Level	I	I	I	I	
Oil (5w - 30 synthetic)		R		R	Every 200 Hours or Annually
Oil Filter		R		R	Every 200 Hours or Annually
COOLING					
Enclosure louvers	I / C	I / C	I / C	I / C	
GENERAL CONDITION					
Vibration, noise, leakage, temp	I	I	I	I	
Battery***	I	I	I	I	
Remove corrosion, ensure dryness	I / C	I / C	I / C	I / C	
Clean and tighten battery terminals	I / C	I / C	I / C	I / C	
Check charge state	I	I	I	I	
Electrolyte level***	I / R	I / R	I / R	I / R	
BATTERY CABLE					
Remove corrosion, clean & tighten	I	I	I	I	
OUTSIDE ENCLOSURE					
Apply conditioner and wax	C	C	C	C	
ENGINE AND MOUNTING					
Air cleaner***		I / R		I / R	
Spark plugs(s)***		I / R		I / R	
Apply corrosion inhibiting spray to engine parts	I	I	I	I	
EXTERNAL CONNECTION BOX					
Tighten terminals	I	I	I	I	
Check for proper operation	I	I	I	I	
Check control wiring connection	I	I	I	I	
ELECTRICAL SYSTEMS					
No load output voltage	I	I	I	I	
Line to line - 240volts	I	I	I	I	
Line to neutral - 120volts	I	I	I	I	
Line to ground - 120volts	I	I	I	I	
Grounding conductor	I	I	I	I	
Earth ground	I	I	I	I	
DC control fuse	I	I	I	I	
Battery charger fuse	I	I	I	I	
Auto/off/manual switch	I	I	I	I	
Levelness of generator	I	I	I	I	

*** Replace as necessary



PREVENTIVE MAINTENANCE SCHEDULE
Liquid Cooled Generator

I - Inspect C - Clean R - Replace

	Year 1		Year 2		Comments
	1st Half	2nd Half	1st Half	2nd Half	
	FUEL				
Fuel Lines and connections	I	I	I	I	
Flexible Fuel Line	I	I	I	I	
LUBRICATION					
Oil Level	I	I	I	I	
Oil (5w - 30 synthetic)		R		R	
Oil Filter		R		R	
COOLING					
Enclosure louvers	I/C	I/C	I/C	I/C	
GENERAL CONDITION					
Vibration, noise, leakage, temp	I	I	I	I	
Battery***	I	I	I	I	
Remove corrosion, ensure dryness	I/C	I/C	I/C	I/C	
Clean and tighten battery terminals	I/C	I/C	I/C	I/C	
Check charge state	I	I	I	I	
Electrolyte level***	I/R	I/R	I/R	I/R	
BATTERY CABLE					
Remove corrosion, clean & tighten	I	I	I	I	
OUTSIDE ENCLOSURE					
Apply conditioner and wax	C	C	C	C	
ENGINE AND MOUNTING					
Air cleaner***		I/R		I/R	
Spark plugs(s)***		I/R		I/R	
Apply corrosion inhibiting spray to engine parts	I	I	I	I	
EXTERNAL CONNECTION BOX					
Tighten terminals	I	I	I	I	
Check for proper operation	I	I	I	I	
Check control wiring connection	I	I	I	I	
ELECTRICAL SYSTEMS					
No load output voltage	I	I	I	I	
Line to line - 240volts	I	I	I	I	
Line to neutral - 120volts	I	I	I	I	
Line to ground - 120volts	I	I	I	I	
Grounding conductor	I	I	I	I	
Earth ground	I	I	I	I	
DC control fuse	I	I	I	I	
Battery charger fuse	I	I	I	I	
Auto/off/manual switch	I	I	I	I	
Levelness of generator	I	I	I	I	

*** Replace as necessary